

# **C P R 32-SE**

## **CONTROL PANEL**

### **FOR**

## **ROGER ACCESS CONTROL SYSTEM**

### **Introduction**

The CPR access control panel is a part of Roger Access Control System (RACS). Generally the device is dedicated for systems which incorporate PR301 and PR201 access controllers but it can also be used with newly developed PRxx2 series (PR302, PR302LCD and PR402). The main function of CPR is to collect all events which occurred on access controllers and save them in its internal memory buffer. When CPR is used with PRxx2 controllers (which are equipped with events memory) it might be used as remote, "high security" events buffer, when CPR operates with PRxx1 controllers it delivers events buffering function plus controls time related functions on controllers (when operating in standalone mode PRxx1 controllers doesn't offer time schedules nor events buffering).

Note: For access systems managed by RACS 3 version software the use of CPR control panels is obligatory, the newly developed RACS 4 access system managing software may operate with systems (or networks) which are equipped with CPR control panels or which are not. When RACS 4 is used to manage access networks which incorporate PR301/201 access controllers but without CPR the RACS 4 delivers real time clock to PR301/201 controllers and register events which occurred in system, without computer in on-line mode both mentioned functionality disappears.

### **Specification**

- 1.5A buffered power supply,
- battery backed up time/date clock,
- flash memory for configuration and events history,
- 256,000 event memory buffer,
- RS485 interface,
- Alarm output,
- TAMPER input,
- battery protection against deep discharge,
- battery charging control circuit,
- metal case with compartment for 7Ah battery.

### **Installation**

Locate the panel in a dry area close to unswitched AC power source. CPR should be mounted in protected location, all electrical connections must be made with power supply off.

Note: You must complete all wiring before connecting the battery, or applying AC to the panel.

Once wiring is complete, power up the control panel. First connect the RED battery lead to the positive terminal and the BLACK to lead to negative. Then, connect the AC. The panel must be thoroughly tested to ensure that all features and functions are operating.

- We recommend to ground AUX minus terminal (connect to earth),
- Do not connect AUX plus output with other supplies plus outputs,
- The minus terminals of each power supply and CPR should be connected together, this will guarantee that each GND will have the same potential referred to earth,
- Do not change settings of potentiometers located on CPR board,
- CPR panel can be connected to RACS communication bus (A and B lines) in any location

### **Memory Reset Procedure**

The MEMORY RESET procedure clears all existing data in CPR memory (configuration settings and events register). The CPR Memory Reset can be performed from PR Master software ("Initialize" command) or can be performed in hardware manner. The second method requires following steps:

- Press Memory Reset switch and keep it pressed,
- While Memory Reset switch is pressed press for a moment uP Reset switch,
- Release Memory Reset switch,
- The entire contents of CPR memory will be erased, panel requires new programming.

Note: The device is delivered with empty (default) configuration settings and do not require the memory reset procedure.

### **Connection Terminals Description**

#### **Battery Connection – RED and BLACK wires**

A 12V 7Ah rechargeable battery is used as a backup source of power in the event of an AC power failure. The battery also provides additional current when the equipment connected to panel demands exceed the power output of the transformer, such as when door strike energizing or activating signaling device (e.g. alarm siren). Electronic circuit monitors reserve battery voltage level, when it falls below -12V the *Low Battery* alarm is signalized, when it falls below -11.5V the *Battery Failure* alarm is signalized, when battery level drop below -10V electronic circuit automatically disconnect battery, entire system goes down. Automatic disconnection of battery protects it from deep discharge and access system from operation below minimum acceptable supply voltage. CPR charges battery with stable current, this method guarantee relatively quick and safe battery charging process. The supply output voltage is factory set to 13.8V but it can vary from 11.0 to 13.8V, this depends on actual battery charging phase. When output level is above 13.5V it means that battery is nearly charged, when levels drop below 12.0V it indicates that battery is on beginning phase of charging.

Note: Do not connect the battery until all other wiring is complete. Connect the battery before connecting AC.

Connect the RED battery lead to the positive battery terminal; connect the black lead to negative.

#### **AC terminals - AC**

The panel requires 18-22V 30VA transformer. Connect the primary side of transformer to unswitched AC source and secondary side to AC terminals.

Note: Do not connect transformer until all other wiring is complete.

#### **Auxiliary Power Terminals – [+AUX-]**

These terminals provide up to 1A of additional current at 12V DC for devices requiring power. Connect the positive side of any device requiring power to AUX+ terminal, the negative side to AUX- (GND-ground). The AUX output is protected, when too much current is drawn from these terminals AUX output will be temporarily shut off until the problem is corrected.

#### **Communication Lines – A and B**

CPR is equipped with RS485 communication interface. This standard of transmission guarantee up to 1200 meters communication distance with high immunity against interferences. Installer may use arbitrary communication bus topology (star, three or any combination of both), no terminating resistors are required. In most cases communication runs satisfactory on almost each types of cables (twisted/untwisted, shielded/unshielded) but it is not guaranteed in each case. Generally unshielded, twisted type cables are preferred and guarantee best performance of communication.

#### **TAMPER Input – IN2**

This input is dedicated to supervise TAMPER contacts of CPR and other devices installed in access system. Normally this input must be shorted to supply minus (GND –ground), this situation is achieved when all TAMPER contacts are closed. If at least one TAMPER contact is open a *TAMPER* alarm is generated.

#### **ALARM Output – REL1 (NO1, COM1, NC1)**

An ALARM line is an open drain, N-MOS type, transistor output. This output can sink up to 1A current for unlimited time. In normal (not triggered) condition output remain in high impedance state, when triggered it move to low resistance state which results that supply minus is observed on output.

#### **Cancel Input – IO1**

This input can be used to cancel alarm signalization on REL1 output and on optional BUZZER connected to IO2 line. This input became triggered when shorted with supply minus (GND - ground).

#### **BUZZER Output – IO2**

This output is dedicated to control an optional BUZZER which can be used to signalize alarm and other condition of CPR control panel. The IO2 line is an open drain transistor output which normally stay in high resistance state, when triggered it switch to supply minus. The maximum current which may be sink by this output is internally limited to 1A value.

Note: BUZZER connect to IO2 output must have internal generator circuit with nominal 12V DC supply voltage.

#### **Additional Supply Terminals – TMS+ and TMS-**

These terminals provide up to 200mA of additional current at 12V DC for devices requiring power. Connect the positive side of any device requiring power to TMS+ terminal, the negative side to TMS- (GND-ground). The TMS output is protected, when too much current is drawn from these terminals TMS output will be temporarily shut off until the problem is corrected.

#### **Reserved Terminals – REL2, IN2, IN3, IN4, CLK, DATA**

Those terminals are reserved for further use, actually they have not assigned any functionality.

## Functional Description

The CPR control panel may operate in ON or OFF mode. When CPR is stay in ON mode it continuously downloads events which had been occurred on all access controllers located in network and save them in its internal memory banks, additionally it controls time related functions (e.g. time schedules) on PR301/PR201 controllers. When CPR stay in OFF mode it stops its normal operation – this mode is dedicated for service purpose only. Generally the CPR control panel is dedicated for access control systems which use PR301 and PR201 controllers. Those controllers are not equipped with internal events buffers nor real time clocks – CPR delivers both this features to PR301/PR201 family. When CPR is used in systems which incorporate PRxx2 series of controllers it operates as remote and high security events buffer only. The PRxx2 controllers are equipped with internal memory buffers and real time clock – the lack of CPR doesn't reduce PRxx2 functionality. The CPR can be used in mixed systems which are equipped with PRxx1 and PRxx2 series controllers, it automatically adopts its operation to different types of controllers which are installed in access network.

## Firmware upgrade

The internal control program of CPR's microcontroller can be upgrade with new firmware versions. The procedure of upgrade is called *flashing* and can be performed by authorized person (installer) without replacement of any memory chips nor returning device to manufacturer. The detailed description of firmware upgrading can be found in *Firmware Upgrade* manual which can be downloaded from [www.roger.pl](http://www.roger.pl)

## Optical and Acoustic signalization

Every alarm situation is signalized through LED located on CPR board and on BUZZER and ALARM outputs. The signalization on ALARM output and Buzzer starts immediately after any alarm situation is detected and ceased automatically after 250 seconds from a moment when last alarm occurred. A signalization on ALARM and BUZZER outputs can be cancelled manually by triggering Cancel Input (IO1) or remotely from supervising PC. A signalization on LED can not be cancelled, it last until last alarm condition disappear. Some of the alarms can be forbidden through PR Master (see CPR settings window from Networks menu).

LED	Description
Tamper	The violation of TAMPER loop was detected, non authorized access to access equipment occurred.
Operation Suspended	CPR set to OFF mode, events registering stopped.
Low Battery	Low level of reserve battery, installer should be called immediately.
AC Lost	Lack of AC supply, signalization occur when CPR detects a lack of AC voltage for 15 minutes period signalization stops immediately after AC supply return.
Memory Full	When this LED blinks, this means that 75% of CPR memory is occupied, operator should transfer the contents of CPR memory to the PC database otherwise the events memory overflow can occur. When this LED is set continuously it indicates that buffer is fully occupied, some events where lost.
TXD	Data transmitted from CPR.
RXD	Data incoming to CPR.

Note: When all LED blinks periodically it means that CPR's settings are corrupted, operator must Reset CPR Memory and then fully download it with new ones.

## Ordering information


<b>CPR32-SE</b>	CPR control panel with metal case.
<b>CPR32-SE-MOD</b>	CPR control panel electronic module (without casings).

## Technical Specification

Power supply	220..230V AC
Power consumption:	30W
Supply Output (nominal)	13.8 V dc
Battery Charging Current	~300 mA
Battery Cut Off Level	~ 10.0 V
Operating temp. range	0...+55° C.
Cable distance between CPR and controller or PC computer	Max. 1200 meters (4000 ft)
Operating humidity	10 to 95% (non condensing)
Dimensions (mm):	280 x 290 x 80
Weight (grams):	~3.5 kG

## Connection terminals assignment

AC	AC supply input, 30VA 18-22VAC transformer	
+ AUX -	Supply output 12V/1A	
NO1	REL1 output, normally open contact	REL1 relay output, 1.5A/24V DC or AC
COM1	REL1 output, common contact	
NC1	REL1 output, normally closed contact	
NO2	REL2 output, normally open contact	REL2 relay output, 1.5A/24V DC or AC
COM2	REL2 output, common contact	
NC2	REL2 output, normally closed contact	
IO1	Transistor output, 1A/16V DC max.	
IO2	Transistor output, 1A/16V DC max.	
IN1	IN1 input line	
COM	IN1 and IN2 common terminal, internally connected with supply minus	
IN2	IN2 input line	
IN3	IN3 input line	
COM	IN3 and IN4 common terminal, internally connected with supply minus	
IN4	IN4 input line	
A	RS485 communication bus, terminal "A"	
B	RS485 communication bus, terminal "B"	
SHLD	RS485 communication bus, cable shield	
CLK	Clock & Data interface, Clock line	
DATA	Clock & Data interface, Data line	
+ TS -	Terminal supply, max. 200mA	



CPR32-SE installation diagram